



**ULTRATECH**  
INTERNATIONAL, INC



## Ultra-Drain Guard® Archaea Boom Model Installation and Maintenance Instructions

Part# 9800 - Ultra-Drain Guard, Archaea Boom Model

### Installation:

1. Remove catch basin grating
2. Clean dirt and debris from grating ledge
3. Unwind the cord attaching the Ultra-Archaea Pillow to the Ultra-Drain Guard.
4. Insert Drain Guard taking care to place the Ultra-Archaea Pillow in the catch basin under the Ultra-Drain Guard.
5. Reinstall grate. To insure maximum effectiveness, Drain Guard skirt should be secured (pinched) between grating and ledge.
6. Cut the excess fabric off with a blade or knife if desired.

### Maintenance and Disposal:

1. The Ultra-Drain Guard filters are designed to be used for at least 3 months under normal conditions. The microbes in the Ultra-Archaea Pillow will remain active for approximately 3 months in the catch basin. Where heavy contamination is present the unit will have a reduced life expectancy. When the unit has collected about 6 inches of sediment or three months have elapsed, it is recommended that it be replaced. The unit should also be replaced if free oil can be seen floating and is not being absorbed. The Ultra-Drain Guards should be inspected on a regular basis.
2. Dispose of unit in accordance with applicable Federal, state and local environmental laws and regulations. The user is solely responsible for compliance with maintenance and disposal laws and regulations. The manufacturer or seller assumes no responsibility for proper or improper maintenance or disposal.